

Auswahltabelle für Cheminée- und Grillanlagen

Typ	Touren- zahl 1/min	Motor- leistung kW	Volumen m ³ /h	stat. Druck bei 20°C Pa	emphohlene Kamingrösse mm	grösste Cheminée- öffnung m ²	grösste Grill- öffnung m ²	passender Regler
HR25	900	0.025	160-550	70-25	160-220	-	-	TE05/FU
	1400	0.06	200-800	150-40	160-220	0.3	-	TE05/FU
HQ30 / HR30	900	0.025	200-1200	90-40	200-250	0.75	-	TE05/FU
	1400	0.12	300-1750	200-80	200-250	-	0.5	TE1/FU
HQ35 / HR35	900	0.06	300-1700	130-30	250-300	1	0.7	TE1/FU
	1400	0.25	400-2200	270-110	250-300	-	1	TE2/FU
HQ45 / HR45	900	0.25	400-3200	280-70	280-400	2	1.6	TE2/FU
	1400	0.75	500-5000	550-120	280-400	-	2.9	FU
HQ55 / HR55	900	0.75	500-6200	450-210	300-500	4	3	FU
	1400	2.2	800-8500	900-500	300-500	-	-	FU